



NOTES:

1. ALL VERTICAL CELLS CONTAINING BAR STEEL SHALL BE FILLED WITH GROUT.
2. TOP OF WALL AND FOOTINGS SHALL BE STEPPED TO CONFORM WITH SLOPE OF GROUND.
3. ALL WALLS SHALL BE PLUMB AND ALL BLOCK COURSES SHALL BE LEVEL.
4. BACKFILL SHALL BE COMPACTED TO A MINIMUM OF 90% OF MAXIMUM DENSITY.
5. FOOTING SHALL BE CLASS 'A' CONCRETE.
6. CONCRETE BLOCK SHALL BE GRADE A UNITS, CONFORMING TO A.S.T.M. DESIGNATION NO. C90.
7. REINFORCING STEEL, GROUT, MORTAR AND CLASS 'A' CONCRETE SHALL CONFORM TO THE STANDARD SPECIFICATIONS. LAP STEEL 20 DIAMETERS.
8. MORTAR TO BE ELIMINATED FROM VERTICAL JOINTS OF ROW OF BLOCKS AT PARKWAY LEVEL.
9. THIS WALL SHALL BE USED WHERE A SCREENING WALL IS REQUIRED ON NON-ACCESS STREET AND THE POSSIBILITY OF BACKFILL ON PRIVATE LOT BY OWNER IS ACCOMPLISHED OR POSSIBLE.
10. DESIGN OF RETAINING WALLS UNDER OTHER CONDITIONS SHALL BE SUBMITTED TO THE COUNTY ENGINEER FOR APPROVAL.

SAN BERNARDINO COUNTY ROAD DEPARTMENT

DATE: J.E.M. 7-66

M. A. Nicholas
COUNTY ENGINEER

RETAINING
CONCRETE BLOCK WALL

301 a