

FIRE HYDRANT



This is a “Blow-Off”.
This is **NOT** an approved hydrant.



This is a “Jones-Head”.
This also is **NOT** an approved hydrant.



This hydrant is approved for applications requiring Fire Flow of **NOT MORE THAN** 1000 gpm. Fire Flow letter shall be submitted with application. **However, it cannot be installed as a new hydrant**



This hydrant is approved for all residential and light commercial applications. Fire Flow letter shall be submitted with application. **This type shall be installed for all new applications**

For residential projects, hydrant must be within 300 feet of project driveway. Hydrant must be located on the address side of the same street the project is located on.