



NOTES:

1. LOCATION OF WATER LINES AND VALVES SHALL BE SHOWN ON THE PLAN VIEW. FOR SUBDIVISION IMPROVEMENT PLANS. SEE HEALTH DEPARTMENT STANDARDS, SECTION 7, DISTRIBUTION SYSTEMS, FOR MINIMUM DEPTH.
2. HYDRANT TO BE SET PLUMB, WITH NOZZLE A MINIMUM OF EIGHTEEN (18") INCHES ABOVE GROUND LEVEL WHEN HYDRANTS ARE PLACED BEFORE GRADING IS COMPLETED, THE FINAL GRADE LINE, AND ACCESSIBILITY SHOULD BE CONSIDERED.
3. NO OBSTRUCTIONS SUCH AS POLES, GUY LINES, ETC. SHOULD BE PLACED CLOSER THAN (5') FEET TO HYDRANT.
4. REFR TO STREET IMPROVEMNT PLANS FOR RIGHT-OF-WAY LOCATION.
5. FOR RECOMMENDED UTILITY LOCATION SEE COUNTY STD. 311
6. FOR CURB RETURN RADIUS & SIDEWALK RAMP DETAILS SEE COUNTY STD. 110

B.C.R. - BEGIN CURB RETURN E.C.R. - END CURB RETURN

CO. OF SAN BDNO. DEPT. OF PUBLIC WORKS		FIRE HYDRANT LOCATION	310
REVISED: DATE G.M. 7-05	PATRICK J. MEAD Director of Public Works		